



NOTES:

1. WATER SERVICES 19mm ϕ AS PER REGION OF DURHAM STD. S-410, AND 25mm ϕ WHERE REQUIRED BY THE TOWN OR REGION.
2. SANITARY SERVICES 100mm ϕ AS PER REGION OF DURHAM STD.'S S-301 & S-302.
3. STORM SERVICES 125mm ϕ AS PER AS-165 & OPSD 1006.01.
4. MINIMUM VERTICAL SEPARATION 0.3m BETWEEN STORM & SANITARY SERVICES.
5. RISER CONNECTIONS MUST BE USED WHEN THE DEPTH TO THE SEWER MAIN EXCEEDS 4.5m RISERS AS PER REGION OF DURHAM STD. S-302.



ENGINEERING SECTION

**SERVICE LOCATION
SEMI DETACHED FAMILY RESIDENTIAL**

DWG. No.

AS-162

DATE

JANUARY 2011

REVISION No.