


NOTES:

- 1.) 100mm P.V.C. TYPE II DUCT REQUIRED UNDER PAVED AREAS
CAPACITY PER DUCT: A) 1-PRIMARY CABLE
B) 2-SECONDARY CABLES
- 2.) TIE TO PROPERTY LINE:
 - 1.85m ON LOCAL RESIDENTIAL STREETS WITH OR WITHOUT 1.25m CONCRETE SIDEWALK
 - 1.50m ON CUL-DE-SACS.
 - 2.10m ON R.O.W, WITH 1.50m CONCRETE SIDEWALK
- 3.) ROAD CROSSING INSTALLED IN CONDUIT AND CONCRETE ENCASED.



ENGINEERING SECTION

**COMMON TRENCH DETAIL FOR
DIRECT BURIED CABLES WITH GAS MAIN**

DWG. No.

AS-173

DATE

JANUARY 2010

REVISION No.