


NOTES:

- ① TREE PROTECTION BARRIERS MUST BE 2.4M (8FT) HIGH, PLYWOOD CLAD HOARDING OR AN EQUIVALENT APPROVED BY DESIGN SERVICES OR ENVIRONMENTAL SERVICES.
- ② PROTECTION BARRIERS FOR TREES SITUATED ON THE TOWN ROAD ALLOWANCE WHERE VISIBILITY MUST BE MAINTAINED CAN BE 1.2M (4FT) HIGH AND CONSIST OF ORANGE PLASTIC WEB SNOW FENCING ON A WOOD FRAME MADE OF 2"X4"S.
- ③ WHERE SOME EXCAVATE OR FILL HAS TO BE TEMPORARILY LOCATED NEAR A TREE PROTECTION BARRIER, PLYWOOD MUST BE USED TO ENSURE NO MATERIAL ENTERS THE TREE PROTECTION ZONE.
- ④ ALL SUPPORTS AND BRACING SHOULD BE OUTSIDE THE TREE PROTECTION ZONE. ALL SUCH SUPPORTS SHOULD MINIMIZE DAMAGING ROOTS OUTSIDE THE TREE PROTECTION BARRIER.
- ⑤ NO CONSTRUCTION ACTIVITY, GRADE CHANGES, SURFACE TREATMENT OR EXCAVATIONS OF ANY KIND IS PERMITTED WITHIN THE TREE PROTECTION ZONE.
- ⑥ TREE PROTECTION BARRIERS TO BE LOCATED MINIMUM 1.0M BEYOND DRIPLINE FOR TREES TO BE PRESERVED.
- ⑦ TREE PROTECTION BARRIERS TO BE INSTALLED BY CONTRACTOR PRIOR TO CONSTRUCTION.
- ⑧ TREE PROTECTION BARRIERS TO BE INSPECTED BY TOWN PRIOR TO CONSTRUCTION.
- ⑨ TREE PROTECTION BARRIERS TO BE MAINTAINED IN GOOD WORKING ORDER.
- ⑩ CONTRACTOR TO REMOVE FENCING AS DIRECTED BY TOWN.



OPERATIONS SECTION

BARRIER - TREE PROTECTION

DWG. No.

AS-705

DATE

SEPT. 2020

REVISION No.