


**NOTES:**

1. CONCRETE TO BE 35MPa COMPRESSIVE STRENGTH AT 28 DAYS WITH 5%-7% AIR ENTRAINMENT
2. PROVIDE EXPANSION JOINTS 4250 MAXIMUM SPACING, SEE SPECIFICATIONS
3. CURBS SHALL BE WOOD OR STEEL FORMED.
4. GENERAL CONTRACTOR IS RESPONSIBLE TO CO-ORDINATE WITH PLAYGROUND CONTRACTOR.
5. THE CONCRETE FOUNDATIONS AND POSTS OF ALL PLAY EQUIPMENT SHALL BE INSTALLED PRIOR TO THE INSTALLATION OF SURFACE AND AFTER THE SUBGRADE ELEVATIONS ARE ESTABLISHED



OPERATIONS SECTION

**CURB - PLAYGROUND CURB  
AND RESILIENT SURFACE**

DWG. No.

**AS-807**

DATE

SEPT. 2020

REVISION No.